



**energysMART**  
Your Efficiency Solutions



## **EnergySmart Residential Standalone Rebates**

*For Homeowners and Ownerships Up To 4 Units*

**Receive 25% of project cost up to \$400**

Attic Insulation with Air Sealing	R-49 minimum required in open attic; cathedral ceilings will vary with rafter depth. Must perform air sealing in attics prior to adding insulation.
Wall Insulation	R-19 minimum; fill wall cavity where R-19 not possible.
Foundation (Basement or Crawl Space) Insulation and Air Sealing	Crawlspace as outlined in the 2012 IECC. R-15 continuous or R-19 Cavity insulation with a vapor-permeable air barrier over insulation. Crawlspace must have sealed vapor barrier over dirt crawl space floor and ventilation, per 2012 IRC.
Gas Furnace Replacement	AFUE $\geq$ 95%, must be sealed combustion
Boiler Replacement	AFUE $\geq$ 90%, must be sealed combustion
ENERGY STAR Air or Ground Source Heat Pump (inc Mini-Splits A/C & Heating units)	Air Source: Split systems $\geq$ 8.5 HSPF/ 15 SEER/12.5 EER. Single systems $\geq$ 8.2 HSPF/15 SEER/12 EER Ground Source: 5.5 tons or smaller
Solar Thermal Space Heating	For use with hydronic (boiler) systems, 20 kW max. size, SRCC rated
ENERGY STAR Gas Water Heater	Min. rating: Tank- .67 EF, On Demand Tankless.90 EF
ENERGY STAR Central Air Conditioner Replacement	15 SEER/12 EER minimum. Requires recycling of existing unit with documentation. Window (single room) units do not qualify
Whole House Evaporative Cooler	Permanent installations only; temporary or portable units are not eligible

Whole House Fan	Fan must have an automated, insulated air sealing mechanism that engages when the fan is off (i.e., doors or damper mechanism, etc). Must have controls (thermostat or timer, multi-speed).
<b>Receive 25% of project cost up to \$50</b>	
Furnace or Boiler Tune-Up	Must be done by a licensed HVAC contractor supplying a detailed invoice. Tune-Ups must include cleaning (inc. filter) and lubrication, with checks on electrical, motors, ignition, thermostat, venting and testing combustion.
Electric Commutated Motor addition on a <u>new</u> furnace replacement	Documentation via the Original Equipment Manufacturer spec sheet is required
ENERGY STAR Dishwasher Replacement	Must be CEE Tier 1 rated in addition to Energy Star certified
ENERGY STAR Refrigerator or Freezer Replacement	Requires recycling of existing unit with supporting documentation. Eligible units must be between 10-30 cubic feet.
Removal of 2 <sup>nd</sup> Refrigerator	Requires recycling of existing unit with supporting documentation

## **Conditions**

- Rebates are only available to **EnergySmart participants** and for the measures listed. Enrollment in EnergySmart must occur **before** purchasing an appliance or completing the energy efficiency project for which a rebate is being applied for.
- **Rebate funds are limited, are subject to change, and will be awarded on a first-come, first-served basis.**
- All work must be completed and invoiced between **September 1, 2016 and December 15, 2016** to qualify for these rebates.
- **Maximum \$900/home** with a **lifetime** EnergySmart maximum of **\$1,500/home** and **\$6,000/owner** of multiple properties (inc. all past and present EnergySmart rebates).
- Multi-Family Units of 5 or more are not eligible for this rebate.
- Rebates cannot exceed the cost of the measure after all other rebates are applied.
- All upgrades must be for or directly benefit unit occupants. (e.g. Only upper units can receive an attic insulation rebate when applying for multiple unit rebates.
- **All work unless noted, must be completed by a contractor participating in EnergySmart's Contractor Partnership Program.** No Do-It-Yourself projects are eligible, except for Refrigerator, Freezer or dishwasher replacement or removal.
- All work must meet all applicable building or energy codes, and all required permits must be obtained. Combustion Appliance Zone (CAZ) testing must occur as a health/safety measure before and after the upgrade depending on the type of upgrade. *Please feel free to speak with your Advisor about the importance of CAZ testing.*